

Dönüşüm Katsayıları / Correction Factors / Korrekturfaktoren :**Tablo-2 / Table-2 / Tabelle-2 (Fe)****R404A**

DT ₁	T _e EVAPORASYON SICAKLIĞI / EVAPORATION TEMPERATURE VERDAMPFUNGSTEMPERATUR (°C)								
	0	-5	-8	-10	-15	-20	-25	-30	-35
6	-	1,29	1,35	1,36	1,40	1,43	1,47	1,52	1,53
7	0,97	1,07	1,15	1,16	1,19	1,22	1,26	1,29	1,31
8	0,85	0,91	1,00	1,01	1,04	1,06	1,09	1,12	1,15
9	0,76	0,78	0,86	0,89	0,92	0,94	0,97	0,99	-
10	0,68	0,68	0,75	0,80	0,82	0,84	0,87	-	-

Tablo-1 / Table-1 / Tabelle-1 (Fg)

Eurovent Şartları Eurovent Conditions Eurovent Bedingungen	Akışkan / Refrigerant Kältemittel		
	R404A/ R507	R22	R134A
SC1 (T _e =0°C DT1=10K)	1	1.05	1.07
SC2 (T _e =-8°C DT1=8K)	1	1.05	1.10
SC3 (T _e =-25°C DT1=7K)	1	1.05	1.18
SC4 (T _e =-31°C DT1=6K)	1	1.05	-